

कार्यालय, कार्यपालन अभियंता लोक स्वास्थ्य यांत्रिकी खंड, कबीरधाम (छ.ग.)

क्र. 2322 जिला जल परीक्षण प्रयोगशाला/का.अ./लो.स्वा.यां. खण्ड/2026 कबीरधाम, दिनांक 7/5/2026

प्रति,

✓ अभ्युदय स्कूल, कवर्धा

पता - कवर्धा

मोबाईल नो - 7771863076

Issue No. ---31---/DL/Date 07/05/2026--


विषय :- जल परीक्षण रिपोर्ट प्रेषित करने बाबत।

संदर्भ :- आपका आवेदन दिनांक 28/04/2026

====000====

विषयान्तर्गत लेख है कि आप के द्वारा जल परीक्षण हेतु जल नमूना इस कार्यालय को प्रस्तुत किया गया था। जिसका परीक्षण रिपोर्ट पत्र के साथ संलग्न कर आपकी ओर प्रेषित है।

संलग्न :- 1. जल परीक्षण रपोर्ट 01 नग।


कार्यपालन अभियंता
लोक स्वास्थ्य यांत्रिकी खण्ड
कबीरधाम (छ.ग.)



District Water Testing Laboratory
Public Health Engineering Department, Division Kabirdham Chhattisgarh
Near Rajmahal Chowk PHE Campus, Phone-07741-233131
e-mail- dwtlaboratorykvdphedcg@gmail.com



Test Report

Discipline- Chemical Testing	Group- Drinking Water
-------------------------------------	------------------------------

ISSUED TO :- Name -- Abhiyuday School Address -- Kawardha Contact No-777186376	REPORT NO.	DL/PHED/KWD/31
	REPORT ISSUED DATE	07/05/2026

SAMPLE PARTICULARS					
DL Receipt No.	31	DL Receipt Date	04.05.2026	Sample collected by	Customer
Date Of Start of Analysis		04.05.2026	Date Of Completion of Analysis		06.05.2026

S.N	Sample I.D.	District /Block	Panchayat / City	Village	Habitation	Location	Type
1	93	Kawardha	Kawardha	Kawardha	Kawardha	School campus	(R.O)

Details of parameters their test method units

S. N.	Parameters	Test method IS:3025/ APHA 24th edition (2023)		Unit	As per BIS -10500 : 2012 For drinking water		Result of S.No.
		Method	Part no.		Accept able Limit	Permissi ble Limit	
1	2	3	4	5	6	7	1
1	Specific Conductivity @25°C	IS:3025	Part-14-2022	µmhos/cm	--	--	Not tested
2	Arsenic (by kit)	BY Kit		mg/l	0.01	No Relaxation	Not tested
3	Manganese as Mn	APHA	Part-3500-Mn-B	mg/l	0.1	0.3	Not tested
4	Residual Chlorine	BY Kit		mg/l	0.2	1.0	Not tested
5	Total Coliform per 100 ml (for Treated water & Distribution system)	APHA	9222-B	24 Hrs	Nil	Nil	Not tested
				48 Hrs	Nil	Nil	Not tested
6	Faecal Coliform / Thermotolerant coliform per 100 ml	APHA	9222-D	24 Hrs	Nil	Nil	Nil

- The report should not be produced partly or full without approval of signatory authority of legal purposes.
- Results apply to the sample as received.

Tested & checked By (Tuleshwar Singh Verma) Lab Assistant & Technical Manager DWTL PHED Kabirdham (C.G)	====End Of Report====	Reviewed & approved By (Gulshan Prasad Sharma) Authorized Signatory Chemist & Quality Manager DWTL PHED Kabirdham (C.G)
---	------------------------------	--